

Registers					
no	Description	mode	repr*	unit	range
0	Type	R		-	1 = Basis 2 = Bypass 3 = Comfort
1	On/Off	R	B	-	0 = Off 1 = On
2	Bypass open temperatuur	R/W	A	°C	15.0 .. 30.0
3	Recirculatie temperatuur	R/W	A	°C	-10.0 .. 30.0
4	Comfort temperatuur	R/W	A	°C	setp min .. setp max
5	Inschakelvertr. Hygr	R/W	B	min	0 .. 120
6	Uitschakelvertr. Hygr.	R/W	B	min	0 .. 120
7	Filter-vuיל tijd	R/W	B	weken	1 .. 99
8	Filtertijd reset	R/W	B	-	0 = Nee 1 = Ja
9	Start maandag dag	R/W	B	min*10	0:00 .. 23:50, OFF
10	Start maandag nacht	R/W	B	min*10	0:00 .. 23:50, OFF
11	Start dinsdag dag	R/W	B	min*10	0:00 .. 23:50, OFF
12	Start dinsdag nacht	R/W	B	min*10	0:00 .. 23:50, OFF
13	Start woensdag dag	R/W	B	min*10	0:00 .. 23:50, OFF
14	Start Woensdag nacht	R/W	B	min*10	0:00 .. 23:50, OFF
15	Start Donderdag dag	R/W	B	min*10	0:00 .. 23:50, OFF
16	Start Donderdag nacht	R/W	B	min*10	0:00 .. 23:50, OFF
17	Start vrijdag dag	R/W	B	min*10	0:00 .. 23:50, OFF
18	Start vrijdag nacht	R/W	B	min*10	0:00 .. 23:50, OFF
19	Start zaterdag dag	R/W	B	min*10	0:00 .. 23:50, OFF
20	Start zaterdag nacht	R/W	B	min*10	0:00 .. 23:50, OFF
21	Start zondag dag	R/W	B	min*10	0:00 .. 23:50, OFF
22	Start zondag nacht	R/W	B	min*10	0:00 .. 23:50, OFF
23	Autom. Zomer/winter tijd	R/W	B	-	0 = nee 1 = ja
24	Vakantie stand actief	R/W	B	-	0 = nee 1 = ja
25	Urenteller laagstand	R	B	uren	-
26	Urenteller middenstand	R	B	uren	-
27	Urenteller hoogstand	R	B	uren	-
28	Urenteller filter	R	B	uren	-